Energy Performance Certificate for Buildings

South End Fire Station & Emergency Services
1696 Walmer Blvrd
South End
Gqeberha
Eastern Cape
6001

Certificate Number: EPC-SA 00501-2025

This certificate is issued in terms of SANS 1544:2014, Energy performance certificates for buildings, and indicates how much energy is being used to operate this building. The energy performance of the building is based on measured energy performance and is compared to the maximum energy consumption provided for in SANS 10400 XA:2021

Energy Performance Certificate

Very energy efficient



SANS 10400-XA:2021 maximum energy consumption in occupancy class in Energy Zone 4

Not energy efficient

Energy performance of your building

1.07 kWh/(m².a)

Energy excluded (outside net floor area) 15.5 kWh/(m².a)

Building Information:
Owner: Nelson Mandela Bay Municipality (NMBM)
Occupancy class/es: G1
Number of floors: 2
Net floor area: 2468.1823
Year of construction: Not Available
Building plan approval: Not Available
Occupancy certificate: Not Available
Year of last major renovation: Unknown
Energy zone: 4
Cadastral information: 1731

Administrative Information:
Registered EPC Professional: Vikash Ramphal
Registration nr: SRP000087
Assessor name: VIKASH RAMPHAL
Date of issue: 2025-07-15
Valid until: 2030-07-14
Record nr: SRP000087

Carrier	Type	From (date)	To (date)	Energy [kWh]	Net Floor Area	Performance [kWh/m²]	Exclusions Performance [kWh/m²]
Grid	Electricity	2024/1/1	2024/12/31	40,915.23	2,468.18	1.07	15.5

HAMSA Consulting Engineers

Registered EPC Professional: Vikash Ramphal

sanedi South African National Energy Development Institute