INFORMAL TENDER ADVERT

NELSON MANDELA BAY MUNICIPALITY
BUDGET AND TREASURY DIRECTORATE
PURCHASING AND STORES DIVISION

Tender Number: GQ11266559
Buyer: Hafkie, Mr NP [00021193]

Closing Date: 2026-11-16
Closing Time: 11:00 A.M

Telephone : 041 506 7630

REFER ALL ENQUIRIES TO THE BUYER

ITEM	QUANTITY	UNIT	KEY WORD	DESCRIPTION	REQUISITION
1	1.00	EACH	SURGE GENERATOR	Supply & deliver surge generator for our Electricity & energy dept,Distributions. Specifications available on N.M.B.M. web-site. Samples / Brochures may be requested from short listed bidders after the tender closing date.Bidders will be required to submit documents within three(3) working days of the request,or within alternative timeframe agreed to in writing with relevant Project manager,failing of bid will be deemed non-responsive & excluded from further evaluation. For further information please contact: Jonathan Davids on cell.no.082 292 3613. E-Mail:jdavids@mandelametro.gov.za	AA193261

THE FOLLOWING CONDITIONS APPLY TO THIS INFORMAL TENDER

- BEFORE COMPLETING THIS FORM, SERVICE PROVIDERS MUST STUDY THE GENERAL CONDITIONS, DEFINITIONS AND DIRECTIVES APPLICABLE IN RESPECT OF SPECIFIC GOALS, AS PRESCRIBED IN THE PREFERENTIAL PROCUREMENT REGULATION OF 2022 THE 80/20 SYSTEM APPLIES TO THIS TENDER.
- Acceptance of this tender submission is subject to the General Conditions of Tender and Conditions of Purchase
- Acceptance of this tender is subject to successful registration on the Nelson Mandela Bay Supplier Database.
- For further information to register, please call Compliance Section @ 041 506 3274
- Failure to comply with these conditions may invalidate your tender submission.
- All tender prices should be valid for a minimum period of thirty (30) days from date of tender.
- ALL TENDER RESPONSES SHOULD BE COMPLETED ONLINE AND NO FAX SUBMISSION WILL BE ACCEPTED BY SUPPLY CHAIN UNIT.

nelson mandela bay
MUNICIPALITY

MEMORANDUM

Tel: +27 (0) 41 392 4111
P O Box 369, Port Elizabeth, 6000
Republic of South Africa

e-Mail:electricity@mandelametro.gov.za

Your ref:

Our ref:

Date: 02 Oct. 2026

Who deals with this: L. Soci & J. Smith

SPECIFICATION OF A SURGE GENERATOR

• DC output power	0 – 4kVcc, 0 – 8kVcc, 0 – 16kVcc
• Peak power per scope	@ 4kVcc – 1000J
	@ 8kVcc – 1000J
	@ 16kVcc – 1000J
• Weight	130kg
• Grounding	Automatic
• Coupler	ARC (Arc Reflection Method) & ICE (Impulse Current Method)
• Dimensions mm.(h x w x d)	650 x 750 x 480 or different
• Power supply	220 Vac /50Hz (110 Vca/60hz optional)
• Operating temperature	-10 °C ... +50 °C

INCLUDED

220 Vac Power Cable

5m Shielded/ Insulated Cable HV Cable

10m Protective Ground Cable

3m external DC power supply cable

Operational Manual